

**BRINNIER and LARIOS, P.C.
PROFESSIONAL ENGINEERS & LAND SURVEYORS**

67 MAIDEN LANE
KINGSTON, NEW YORK 12401

–
TELEPHONE (845) 338-7622
FAX (845) 338-7660

DESIGN
REPORTS
SUPERVISION
CONSULTING SERVICES

SUBDIVISIONS
TITLE SURVEYS
TOPOGRAPHIC SURVEYS

ADDENDUM NO. 2

CONTRACT NO. VNP-191


CONSENT ORDER COMPLIANCE SEWER REMEDIATION

CDBG PROJECT NO. 1793PR104-18

VILLAGE OF NEW PALTZ

ULSTER COUNTY, NEW YORK

March 11, 2020



SPECIFICATIONS:

Page 9

INSTRUCTIONS TO BIDDERS – BID PROPOSAL FORM – Item No. 11 – **delete quantity and replace with 4,000 SY.** See below.

ITEM NO.	APPROX. QUANTITIES	DESCRIPTION OF ITEMS IN WORDS (WRITTEN)	<u>UNIT PRICE</u>		<u>AMOUNT</u>	
			Dollars	Cents	Dollars	Cents
11	4,000 SY	Furnish & Install 1 1/2" Asphaltic Pavement Overlay, Complete, for the Unit Price of _____				

Page 03500-1

SECTION 03500 – CURED-IN-PLACE PIPE (CIPP) – PART 1 – GENERAL – 1.01 INTENT – Subsection B. and C. **delete** in their entirety.

Page 03500-1

SECTION 03500 – CURED-IN-PLACE PIPE (CIPP) – PART 1 – GENERAL – 1.02 SUMMARY – B. Work Included: Subsection e. **delete** in its entirety.

SPECIFICATIONS: (Con't)

Page 03500-4 SECTION 03500 – CURED-IN-PLACE PIPE (CIPP) – PART 1 – GENERAL – 1.06 SUBMITTALS – Subsection B. 5. **delete** every sentence **after** second sentence “The calculated thickness for the CIPP felt liner.....”.

Page 03500-6 SECTION 03500 – CURED-IN-PLACE PIPE (CIPP) – PART 2 – PRODUCTS – 2.04 CURED-IN-PLACE LINER – Subsection C. **delete** “epoxy vinyl ester resin” and **replace** with “polyester resin.”

END OF ADDENDUM NO. 2